



Sprinkler Systems – Jan 01, 2019

- NFPA 13, except



NFPA 13R – buildings up to 6 storeys high

NFPA 13D - buildings up to 3 storeys high, and
- sleeping provided for up to 10

Div B – 9.7.5.1.



Sprinkler Systems – Exception

- Not required in buildings up to 3 storeys if
- sleeping for no more than 4 persons, and,
 - interconnected smoke alarm system provided



Div B – 9.7.5.1.



Pause





Regulations – Effective January 1, 2014

150/13 – Amendment to the Fire Code

**364/13 – Mandatory Inspection and Fire Drill
in Vulnerable Occupancy**

365/13 – Mandatory Assessment of Complaints and
Requests for Approval



Ontario Regulation 364/13

Upon notification of the fire drill for the approved scenario, the prescribed person (Fire Service) must:

- Ensure that an inspector observes the fire drill,
- Ensure that an inspector conducts a fire safety inspection in accordance with directives issued by the Fire Marshal, and
- File the following information with the Fire Marshal as directed by the Fire Marshal: operating name, address, occupancy classification, date the fire drill was observed and date the inspection was conducted.



FM Directives – Effective January 1, 2014

2014-001: Registry of Vulnerable Occupancies

2014-002: Vulnerable Occupancies:

- Fire Drill Scenarios and Observations**
- Fire Safety Inspections**

2014-003: Inspections of All Buildings



FM Directive 2014-002

Directs Chief Fire Officials to agree on and approve:

- A fire drill scenario as prescribed in this directive, and
- A notification period.



FM Directive 2014-002, cont'd

Directs Assistants to the Fire Marshal:

- To observe the fire drill, and
- Carry out an inspection to assess compliance with an inspection checklist (attached to the directive).



Regulations – Effective January 1, 2014

150/13 – Amendment to the Fire Code

364/13 – Mandatory Inspection and Fire Drill
in Vulnerable Occupancy

**365/13 – Mandatory Assessment of Complaints
and Requests for Approval**



Ontario Regulation 365/13

A prescribed person (fire service) who receives a complaint about fire safety in a building must assess the complaint to determine if an inspection is advisable.



Ontario Regulation 365/13, cont'd

A Chief Fire Official who receives a request for approval with respect to the fire code must assess the request and determine if an inspection is advisable.



Ontario Regulation 365/13, cont'd

Assessment of complaints or requests for approval must comply with FM directives.

Inspections must comply with FM directives.



Ontario Regulation 365/13, cont'd

If an inspection is conducted, the inspectors must file the following information with the Fire Marshal:

- operating name and address
- occupancy classification
- date the inspection was conducted.



FM Directives – Effective January 1, 2014

2014-001: Registry of Vulnerable Occupancies

2014-002: Vulnerable Occupancies:

- Fire Drill Scenarios and Observations
- Fire Safety Inspections

2014-003: Inspections of All Buildings



FM Directive 2014-003

Directs Assistants to the Fire Marshal to

- assess complaints and
- conduct fire safety inspections

arising from O. Reg. 365/13 in accordance with the guideline referenced in this directive.



FM Directives – Effective January 1, 2014

2014-001: Registry of Vulnerable Occupancies

2014-002: Vulnerable Occupancies:

- Fire Drill Scenarios and Observations
- Fire Safety Inspections

2014-003: Inspections of All Buildings



FM Directive 2014-001

Directs Assistants to the Fire Marshal to file information required in O. Reg. 364/13 and O. Reg. 365/13 by the end of the month following the date when the inspection is completed.



The End

